



पचरौता नगरपालिका
Pachrauta Municipality
नगर कार्यपालिकाको कार्यालय

Office of the Municipal executive

पत्र संख्या/Letter No: २०८१/०८२

चलानी नं./Ref No: ३२३६



बेनीली, बारा/Benauli, Bara
मधेश प्रदेश/Province-2, Nepal

मिति: २०८२/०२/०७

विषय: दररेट पेश गर्ने सम्बन्धमा।

श्री सम्बन्धित सबै।

प्रस्तुत विषयमा यस नगरपालिकाको पशु सेवा शाखाको आ.व २०८१/०८२ ससर्त अनुदान कार्यक्रम अन्तर्गत कोल्ड च्याम्बर निर्माण कार्यक्रमको स्पेसिफिकेशन अनुसार लागत इस्टिमेट तयार गर्नको लागि दररेट पेश गर्नु हुन यो सुचना प्रकाशित भएको मितिले ३(तीन) भित्र दररेट पेश गर्नुहुन यो सुचना प्रकाशित गरिएको व्यहोरा अनुरोध छ।

वसन्तराज जोशी

प्रमुख प्रशासकीय अधिकृत

प्रमुख प्रशासकीय अधिकृत

मो.नं. ९८५५०४८४६४ | वेबसाइट : www.pachrautamun.gov.np | ईमेल : pachrautamun@gmail.com
ट्विटर: twitter.com/pcharauta

"सुन्दर, स्वच्छ, समृद्ध, पचरौता: कृषी, शिक्षा, पूर्वाधार र सम्पदा"



पचरौता नगरपालिका
Pachrauta Municipality
नगर कार्यपालिकाको कार्यालय

Office of the Municipal executive

पत्र संख्या/Letter No: २०८१/८२

चलानी नं./Ref No:

बेनीली, बारा/Benauli, Bara

मधेश प्रदेश/Madhesh Province, Nepal

QUOTATION

Cold Room Dimension	: Outer Dimension (ft) : 11.42' x 9.51' x 8' Outer Dimension (m) : 3.48m x 2.9m x 2.44m Inner Dimension (ft) : 10.76' x 8.86' x 7.35' Inner Dimension (m) : 3.28m x 2.7m x 2.24m 1 nos
No. of Chambers	: 700.7
Gross Internal Volume (C.F.T)	: Curd
Product/ Item	: Storage Room
Room Type- Vapour Proof Light -	: Yes, Qty. As per Requirement
Approx Storage Quantity (MT)	: NA
Loading Per Batch	: 300 to 400 kg per day
Pull Down Time	: Approx 16 hrs
Room Temperature	: 2°C to 4°C
Product Incoming Temperature	: 30°C
Panel Construction	: Tongue & Groove mechanism along with wall to wall, Wall to ceiling and wall to floor camlocks to provide high Standard insulation
Blowing Agent	: HFC-245fa, which is a HCFC free, fully blended HFC co-blown System with zero ozone depletion 1.5 – 1.8
PUF close cell content	: Greater than 90 %
PUF Thermal Conductivity (W/Mk)	: 0.022 - 0.024
Wall/Ceiling/Floor Panel Insulation	: PUF (Poly-urethane foam) with density 40±2 kg/m3
Wall/Ceiling Panel Thickness	: 100 mm
Wall/Ceiling Panel Surface Material	: Inside and Outside PPGI (Pre-Painted Galvanized Sheet) sheet
Floor Panel Surface Material	: Thickness: 0.45 mm – Floor Panel Thickness : 100 mm : Inside & Outside PPGI (Pre-Painted Galvanized Sheet) sheet Thickness: 0.45 mm
Number Of Doors	: 1 nos

Handwritten signature



पचरौता नगरपालिका
Pachrauta Municipality
नगर कार्यपालिकाको कार्यालय

Office of the Municipal executive

पत्र संख्या/Letter No: २०८१/८२

चलानी नं./Ref No:

बेनीली, बारा/Benauli, Bara

मधेश प्रदेश/Madhesh Province, Nepal

Door Opening (W x H)
Door Gasket
Door Accessories

: 774mm x 1835mm (Standard opening)
: All inside mantetic gasket (Non Trolley Use)
: Thermally sealed flush Type swing door
With heavy duty hinges and handles with
door closer for push type gasket which is
easy to operate and has a long life.
: Yes. It will be installed in the door frame
Or adjacent wall panel to the
: Kick Plate is available on the outside of the door
: Safety Release Knob is placed at the inner
Of the door for safety precautions.

❖ 2 Refrigeration Unit CR-41 3ph

Refrigeration Unit Model
Refrigeration Unit Type
Condense Type
Compressor Make
Compressor Type
Compressor Power
Evaporating Coil
Power Consumption
Power Supply
Defrosting method
Refrigerant
Evaporator Model
Evaporator Body Dimension
Evaporator Fan Dia / Qty
Evaporator CMH / Throw

: CR-41
: Air cooled split type
: Air-cooled Almunium and copper tube type
: Emerson/Copeland
: Hermatic Reciprocating
: 3 HP
: Aluminium fin and copper tube type
: 3.27 KW
: 440 Volt, 50 Hz, 3 Phase
: Air Defrost
: R-407c
: A7032303A
: 58" x 13" x 16"
: Fan Dia: 300 mm / Qty: 3 nos
: CMH: 4680 m³ / Throw: 10m

Delivered